


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:240.3V I:0.0266A P:5.6W PF:0.8678 Freq:49.99Hz		
UTHDi:0.17% ITHDi:24.56% KDisp:0.8946 Lamp Flux:353.119x1 lm		
NAME: MD10-06-XX-16 2700K RA90 18D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.: 26mm	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 63.57 lm/W
MODEL		I _{max} (cd)	1452	S/MH (C0/180)		0.42
NOMINAL POWER(W)	6	LOR (%)	100.0	S/MH (C90/270)		0.39
RATED VOLTAGE(V)	240	TOTAL FLUX(lm)	353.12	η UP,DN (C0-180)		0.0,54.3
NOMINAL FLUX(lm)	353.119	CIE CLASS	DIRECT	η UP,DN (C180-360)		0.0,45.7
LAMPS INSIDE	1	η up (%)	0.0	CIBSE SHR NOM		0.00
TEST VOLTAGE(V)	240.29	η down (%)	100.0	CIBSE SHR MAX		0.30

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



PLANAR ISOLUX DIAGRAM (UNIT: lx)



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: MEDIUM
Temperature: 25.3DEG
Operators: DAMIN
Test Date: 2024-03-16

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity: 65.0%
Test Distance: 3.090m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	1010	1054	1081	1086	984.6	936.5	899.1	950.7	0- 10	116.5	116.5	33,33
20	232.4	276.1	276.2	261.1	202.3	176.0	169.1	193.9	10- 20	150.2	266.7	75.5,75.5
30	45.05	52.12	52.30	48.18	40.35	38.44	37.61	40.03	20- 30	45.89	312.6	88.5,88.5
40	20.04	21.78	21.79	20.10	17.76	17.24	17.33	18.45	30- 40	17.59	330.1	93.5,93.5
50	10.53	11.44	11.88	11.02	10.28	10.01	9.589	9.855	40- 50	11.36	341.5	96.7,96.7
60	4.452	4.778	5.166	4.834	4.626	4.468	4.263	4.390	50- 60	6.428	347.9	98.5,98.5
70	2.088	2.216	2.453	2.241	2.145	2.106	2.004	2.125	60- 70	3.174	351.1	99.4,99.4
80	0.9753	1.091	1.153	1.030	0.9648	0.9449	0.8627	0.9653	70- 80	1.624	352.7	99.9,99.9
90	0.0083	0.0061	0.0090	0.0039	0.0048	0.0058	0.0087	0.0074	80- 90	0.3837	353.1	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 336.41 lm

%lum = 95.3%

%lamp = 95.3%

Conical surface Flux(120deg): 347.94 lm

%lum = 98.5%


%lamp = 98.5%

C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: MEDIUM
 Temperature:25.3DEG
 Operators:DAMIN
 Test Date:2024-03-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
 Humidity:65.0%
 Test Distance:3.090m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:240.3V I:0.0266A P:5.6W PF:0.8678 Freq:49.99Hz		
UTHDi:0.17% ITHDi:24.56% KDisp:0.8946 Lamp Flux:353.119x1 lm		
NAME: MD10-06-XX-16 2700K RA90 18D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.: 26mm	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: MEDIUM
Temperature: 25.3DEG
Operators: DAMIN
Test Date: 2024-03-16

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity: 65.0%
Test Distance: 3.090m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:240.3V I:0.0266A P:5.6W PF:0.8678 Freq:49.99Hz		
UTHDi:0.17% ITHDi:24.56% KDisp:0.8946		
Lamp Flux:353.119x1 lm		
NAME: MD10-06-XX-16 2700K RA90 18D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.: 26mm	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0
p _w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
p _{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Coefficients of Utilization(CU)															
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.12	1.10	1.08	1.10	1.08	1.07	1.06	1.05	1.03	1.02	1.01	1.00	.99	.98	.97	.96
2.0	1.06	1.03	1.00	1.05	1.02	.99	1.02	.99	.97	.99	.97	.95	.96	.94	.93	.92
3.0	1.01	.97	.94	.90	.96	.93	.97	.94	.92	.95	.93	.90	.93	.91	.89	.88
4.0	.97	.92	.89	.96	.92	.89	.94	.90	.88	.92	.89	.87	.90	.88	.86	.84
5.0	.93	.88	.85	.92	.88	.85	.90	.87	.84	.89	.86	.83	.87	.85	.83	.81
6.0	.89	.85	.81	.89	.84	.81	.87	.83	.81	.86	.83	.80	.85	.82	.80	.79
7.0	.86	.82	.78	.86	.81	.78	.84	.81	.78	.83	.80	.77	.82	.79	.77	.76
8.0	.83	.79	.76	.83	.79	.76	.82	.78	.75	.81	.77	.75	.80	.77	.75	.74
9.0	.81	.76	.73	.80	.76	.73	.79	.76	.73	.79	.75	.73	.78	.75	.73	.72
10.0	.78	.74	.71	.78	.74	.71	.77	.73	.71	.76	.73	.71	.76	.73	.70	.70



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: MEDIUM
Temperature:25.3DEG
Operators:DAMIN
Test Date:2024-03-16

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:240.3V I:0.0266A P:5.6W PF:0.8678 Freq:49.99Hz		
UTHDi:0.17% ITHDi:24.56% KDisp:0.8946 Lamp Flux:353.119x1 lm		
NAME: MD10-06-XX-16 2700K RA90 18D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.: 26mm	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)										
0.0																	
1.0	.149	.085	.027	.143	.081	.026	.130	.075	.024	.119	.069	.022	.108	.063	.020		
2.0	.139	.076	.023	.134	.074	.023	.123	.069	.021	.114	.064	.020	.105	.059	.019		
3.0	.130	.069	.021	.125	.067	.020	.117	.063	.019	.109	.060	.018	.101	.056	.017		
4.0	.122	.063	.019	.118	.062	.018	.110	.059	.017	.104	.056	.017	.097	.053	.016		
5.0	.114	.058	.017	.111	.057	.017	.105	.055	.016	.099	.052	.016	.093	.050	.015		
6.0	.108	.054	.015	.105	.053	.015	.100	.051	.015	.095	.049	.014	.090	.047	.014		
7.0	.102	.051	.014	.100	.050	.014	.095	.048	.014	.091	.046	.014	.086	.045	.013		
8.0	.097	.047	.013	.095	.047	.013	.091	.045	.013	.087	.044	.013	.083	.043	.012		
9.0	.093	.045	.013	.091	.044	.012	.087	.043	.012	.084	.042	.012	.080	.041	.012		
10.0	.088	.042	.012	.087	.042	.012	.083	.041	.012	.080	.040	.011	.077	.039	.011		

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)										
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020		
1.0	.169	.158	.147	.145	.135	.127	.099	.093	.088	.057	.054	.051	.018	.017	.016		
2.0	.152	.133	.116	.130	.114	.101	.089	.079	.070	.051	.046	.041	.016	.015	.013		
3.0	.138	.113	.094	.118	.098	.082	.081	.068	.057	.047	.040	.034	.015	.013	.011		
4.0	.125	.098	.077	.108	.085	.067	.074	.059	.047	.043	.035	.028	.014	.011	.009		
5.0	.115	.086	.064	.099	.074	.056	.068	.052	.040	.039	.031	.023	.013	.010	.008		
6.0	.106	.076	.054	.092	.066	.047	.063	.046	.033	.037	.027	.020	.012	.009	.007		
7.0	.099	.068	.046	.085	.059	.040	.059	.041	.029	.034	.024	.017	.011	.008	.006		
8.0	.092	.061	.040	.080	.053	.035	.055	.037	.025	.032	.022	.015	.010	.007	.005		
9.0	.087	.056	.035	.075	.048	.030	.052	.034	.022	.030	.020	.013	.010	.007	.004		
10.0	.082	.051	.031	.071	.044	.027	.049	.031	.019	.029	.018	.011	.009	.006	.004		

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: MEDIUM
Temperature:25.3DEG
Operators:DAMIN
Test Date:2024-03-16

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:240.3V I:0.0266A P:5.6W PF:0.8678 Freq:49.99Hz UTHDi:0.17% ITHDi:24.56% KDisp:0.8946 Lamp Flux:353.119x1 lm										
NAME: MD10-06-XX-16 2700K RA90 18D					TYPE:			WEIGHT:		
SPEC.:					DIM.:			SERIAL No.:		
MFR.: Norming Lighting					SUR.: 26mm			Shielding Angle:		
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	17.9	18.6	18.1	18.7	18.9	18.3	19.0	18.5	19.2	19.4
3H	18.2	18.9	18.5	19.1	19.3	18.7	19.4	19.0	19.6	19.8
4H	18.4	19.0	18.6	19.2	19.4	18.9	19.5	19.2	19.7	20.0
6H	18.5	19.1	18.8	19.3	19.6	19.1	19.7	19.4	19.9	20.1
8H	18.6	19.1	18.9	19.4	19.6	19.1	19.7	19.4	19.9	20.2
12H	18.6	19.1	18.9	19.4	19.7	19.1	19.6	19.4	19.9	20.1
4H 2H	18.0	18.7	18.3	18.9	19.1	18.4	19.1	18.7	19.3	19.5
3H	18.5	19.0	18.8	19.3	19.6	18.9	19.5	19.2	19.8	20.0
4H	18.7	19.2	19.1	19.5	19.8	19.2	19.7	19.5	20.0	20.3
6H	19.0	19.4	19.3	19.7	20.1	19.5	19.9	19.9	20.3	20.6
8H	19.1	19.5	19.4	19.8	20.2	19.5	20.0	19.9	20.3	20.7
12H	19.1	19.5	19.5	19.8	20.2	19.5	19.9	19.9	20.3	20.6
8H 4H	18.8	19.2	19.2	19.5	19.9	19.2	19.7	19.6	20.0	20.4
6H	19.1	19.5	19.5	19.9	20.3	19.6	20.0	20.0	20.4	20.8
8H	19.3	19.6	19.7	20.0	20.4	19.7	20.0	20.2	20.4	20.9
12H	19.3	19.6	19.8	20.0	20.5	19.7	19.9	20.1	20.4	20.8
12H 4H	18.8	19.1	19.2	19.5	19.9	19.2	19.6	19.6	20.0	20.4
6H	19.1	19.5	19.6	19.9	20.3	19.6	19.9	20.1	20.4	20.8
8H	19.3	19.6	19.8	20.0	20.5	19.7	20.0	20.2	20.4	20.9
Variations with the observer position at spacings(CIE Pub.117):										
S = 1.0H	+ 0.8 / - 1.1					+ 0.8 / - 1.0				
1.5H	+ 0.7 / - 0.8					+ 0.8 / - 0.8				
2.0H	+ 1.9 / - 1.4					+ 1.9 / - 1.5				

CIE Pub.117, 353.1 lm Total Lamp Luminous Flux Corrected (8log(F/F0) = -3.6)
Area: 0.0005 m2

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: MEDIUM
Temperature:25.3DEG
Operators:DAMIN
Test Date:2024-03-16

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:240.3V I:0.0266A P:5.6W PF:0.8678 Freq:49.99Hz		
UTHDi:0.17% ITHDi:24.56% KDisp:0.8946 Lamp Flux:353.119x1 lm		
NAME: MD10-06-XX-16 2700K RA90 18D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.: 26mm	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	87	81	77	87	81	77	86	81	77	74
0.80	95	89	85	94	89	85	93	88	85	81
1.00	99	94	90	98	93	90	97	93	89	85
1.25	103	98	95	102	97	94	100	96	93	89
1.50	106	101	98	105	100	97	102	99	96	92
2.00	108	104	101	107	103	100	104	101	99	94
2.50	110	106	103	109	105	102	105	103	101	95
3.00	112	108	106	110	107	104	107	104	102	96
4.00	114	111	109	112	109	107	108	106	105	98
5.00	115	113	111	113	111	109	109	108	106	99
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: MEDIUM
Temperature:25.3DEG
Operators:DAMIN
Test Date:2024-03-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:240.3V I:0.0266A P:5.6W PF:0.8678 Freq:49.99Hz		
UTHDi:0.17% ITHDi:24.56% KDisp:0.8946 Lamp Flux:353.119x1 lm		
NAME: MD10-06-XX-16 2700K RA90 18D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.: 26mm	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: MEDIUM
Temperature:25.3DEG
Operators:DAMIN
Test Date:2024-03-16

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

AAI Figure

Test:U:240.3V I:0.0266A P:5.6W PF:0.8678 Freq:49.99Hz		
UTHDi:0.17% ITHDi:24.56% KDisp:0.8946		Lamp Flux:353.119x1 lm
NAME: MD10-06-XX-16 2700K RA90 18D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.: 26mm	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: MEDIUM
Temperature:25.3DEG
Operators:DAMIN
Test Date:2024-03-16

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

ISOLUX DIAGRAM

Test:U:240.3V I:0.0266A P:5.6W PF:0.8678 Freq:49.99Hz		
UTHDi:0.17% ITHDi:24.56% KDisp:0.8946 Lamp Flux:353.119x1 lm		
NAME: MD10-06-XX-16 2700K RA90 18D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.: 26mm	Shielding Angle:



C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: MEDIUM
 Temperature:25.3DEG
 Operators:DAMIN
 Test Date:2024-03-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
 Humidity:65.0%
 Test Distance:3.090m [K=1.0000]
 Remarks:

LED Avg.L Report

Test:U:240.3V I:0.0266A P:5.6W PF:0.8678 Freq:49.99Hz		
UTHDi:0.17% ITHDi:24.56% KDisp:0.8946 Lamp Flux:353.119x1 lm		
NAME: MD10-06-XX-16 2700K RA90 18D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.: 26mm	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	14442
L_0~180 (75) av	11332
L_0~180 (85) av	7308
L_90~270 (65) av	15137
L_90~270 (75) av	12008
L_90~270 (85) av	1693
L_45 (65) av	14749
L_45 (75) av	11744
L_45 (85) av	7254

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: MEDIUM
Temperature:25.3DEG
Operators:DAMIN
Test Date:2024-03-16

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: MEDIUM
 Temperature: 25.3DEG
 Operators: DAMIN
 Test Date: 2024-03-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
 Humidity: 65.0%
 Test Distance: 3.090m [K=1.0000]
 Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

```

Photometric Data Table [cd]

G/C	0.0	45.0	90.0	135.0	180.0	225.0	270.0	315.0
0.0	1447	1447	1447	1447	1447	1447	1447	1447
3.0	1405	1423	1433	1431	1405	1382	1375	1385
6.0	1285	1312	1335	1335	1278	1237	1219	1248
9.0	1090	1128	1156	1162	1070	1023	989.2	1036
12.0	834.7	894.1	914.2	913.9	800.1	750.6	710.0	766.0
15.0	564.3	636.6	644.2	631.1	520.4	473.1	442.2	494.8
18.0	339.5	399.1	399.6	382.9	300.3	264.3	249.7	286.7
21.0	191.6	228.3	228.0	218.8	166.2	144.9	140.1	159.8
24.0	109.7	129.7	129.1	121.1	95.58	85.90	83.76	94.91
27.0	67.79	78.82	78.87	73.18	59.65	55.49	54.20	58.71
30.0	45.05	52.12	52.30	48.18	40.35	38.44	37.61	40.03
33.0	32.56	37.16	37.29	34.39	29.36	28.25	27.81	29.48
36.0	25.52	28.48	28.51	26.32	22.87	22.06	21.88	23.35
39.0	21.16	23.16	23.17	21.30	18.76	18.19	18.26	19.45
42.0	17.99	19.46	19.55	18.02	16.05	15.65	15.68	16.60
45.0	15.12	16.28	16.52	15.25	13.85	13.55	13.41	13.95
48.0	12.32	13.31	13.72	12.68	11.73	11.44	11.09	11.41
51.0	9.711	10.53	10.96	10.22	9.560	9.284	8.864	9.115
54.0	7.502	8.133	8.552	8.014	7.575	7.308	6.944	7.151
57.0	5.754	6.212	6.626	6.213	5.905	5.693	5.422	5.585
60.0	4.452	4.778	5.166	4.834	4.626	4.468	4.263	4.390
63.0	3.484	3.725	4.069	3.791	3.640	3.530	3.379	3.480
66.0	2.771	2.953	3.248	3.008	2.890	2.815	2.691	2.791
69.0	2.238	2.377	2.627	2.409	2.306	2.264	2.157	2.274
72.0	1.816	1.936	2.141	1.939	1.851	1.826	1.724	1.858
75.0	1.460	1.575	1.736	1.549	1.473	1.459	1.372	1.496
78.0	1.171	1.274	1.385	1.218	1.151	1.147	1.073	1.180
81.0	0.8699	0.9867	0.9337	0.9377	0.8686	0.8363	0.7406	0.8447
84.0	0.4400	0.5381	0.0543	0.6116	0.5296	0.4236	0.2901	0.3583
87.0	0.0262	0.0224	0.0071	0.0786	0.0891	0.0237	0.0109	0.0071
90.0	0.0083	0.0061	0.0090	0.0039	0.0048	0.0058	0.0087	0.0074

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: MEDIUM
Temperature:25.3DEG
Operators:DAMIN
Test Date:2024-03-16

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks: