


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:240.4V I:0.0448A P:10.0W PF:0.9321 Freq:49.99Hz		
UTHDi:0.14% ITHDi:20.02% KDisp:0.9515 Lamp Flux:929.46lx1 lm		
NAME: MD10-10-XX-01 3000K RA90 15D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 92.57 lm/W
MODEL		I _{max} (cd)	6153	S/MH (C0/180)	0.31	
NOMINAL POWER(W)	10	LOR (%)	100.0	S/MH (C90/270)	0.31	
RATED VOLTAGE(V)	240	TOTAL FLUX(lm)	929.46	η UP,DN (C0-180)	0.0,48.6	
NOMINAL FLUX(lm)	929.461	CIE CLASS	DIRECT	η UP,DN (C180-360)	0.0,51.4	
LAMPS INSIDE	1	η up (%)	0.0	CIBSE SHR NOM	0.00	
TEST VOLTAGE (V)	240.40	η down (%)	100.0	CIBSE SHR MAX	0.30	

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



PLANAR ISOLUX DIAGRAM (UNIT: lx)



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: DAMIN
Test Date: 2023-09-14

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity: 65.0%
Test Distance: 3.090m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	2454	2458	2488	2603	2675	2690	2628	2481	0- 10	381.0	381.0	41,41
20	535.2	498.1	458.8	471.7	509.1	535.4	550.7	546.8	10- 20	324.0	705.0	75.9,75.9
30	175.5	153.7	130.5	133.3	149.1	158.2	167.1	172.5	20- 30	133.6	838.6	90.2,90.2
40	52.96	43.83	36.26	36.90	42.52	43.78	46.70	49.89	30- 40	54.68	893.3	96.1,96.1
50	16.22	13.52	11.52	11.98	13.94	13.77	13.36	14.34	40- 50	19.17	912.5	98.2,98.2
60	8.433	7.929	7.317	7.276	7.792	7.824	7.763	7.934	50- 60	8.891	921.4	99.1,99.1
70	4.046	4.055	3.913	3.914	3.929	4.117	4.281	4.173	60- 70	5.927	927.3	99.8,99.8
80	0.4282	0.4165	0.4057	0.3961	0.4054	0.3816	0.2809	0.3651	70- 80	2.031	929.3	100,100
90	0.0138	0	0.0174	0	0	0	0.0071	0	80- 90	0.1316	929.5	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 905.31 lm

%lum = 97.4%

%lamp = 97.4%

Conical surface Flux(130deg): 924.74 lm

%lum = 99.5%


%lamp = 99.5%

C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:DAMIN
 Test Date:2023-09-14

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
 Humidity:65.0%
 Test Distance:3.090m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:240.4V I:0.0448A P:10.0W PF:0.9321 Freq:49.99Hz		
UTHDi:0.14% ITHDi:20.02% KDisp:0.9515 Lamp Flux:929.46lx1 lm		
NAME: MD10-10-XX-01 3000K RA90 15D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.:	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: DAMIN
Test Date: 2023-09-14

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity: 65.0%
Test Distance: 3.090m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:240.4V I:0.0448A P:10.0W PF:0.9321 Freq:49.99Hz		
UTHDi:0.14% ITHDi:20.02% KDisp:0.9515 Lamp Flux:929.46lx1 lm		
NAME: MD10-10-XX-01 3000K RA90 15D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.:	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio															



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2023-09-14

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:240.4V I:0.0448A P:10.0W PF:0.9321 Freq:49.99Hz		
UTHDi:0.14% ITHDi:20.02% KDisp:0.9515 Lamp Flux:929.461x1 lm		
NAME: MD10-10-XX-01 3000K RA90 15D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.:	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)									
0.0																
1.0	.140	.080	.025	.134	.076	.024	.121	.070	.022	.110	.063	.020	.099	.058	.019	
2.0	.131	.072	.022	.125	.069	.021	.115	.064	.020	.105	.059	.019	.097	.055	.017	
3.0	.122	.065	.019	.117	.063	.019	.109	.059	.018	.101	.055	.017	.093	.052	.016	
4.0	.114	.059	.017	.110	.058	.017	.103	.055	.016	.096	.052	.016	.090	.049	.015	
5.0	.107	.055	.016	.104	.053	.016	.098	.051	.015	.092	.048	.014	.086	.046	.014	
6.0	.101	.051	.014	.098	.050	.014	.093	.048	.014	.088	.046	.013	.083	.044	.013	
7.0	.096	.047	.013	.093	.046	.013	.089	.045	.013	.084	.043	.013	.080	.042	.012	
8.0	.091	.044	.012	.089	.044	.012	.085	.042	.012	.081	.041	.012	.077	.040	.012	
9.0	.087	.042	.012	.085	.041	.012	.081	.040	.011	.078	.039	.011	.075	.038	.011	
10.0	.083	.040	.011	.081	.039	.011	.078	.038	.011	.075	.037	.011	.072	.036	.010	

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)										
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020		
1.0	.169	.158	.148	.144	.135	.127	.099	.093	.088	.057	.054	.051	.018	.017	.017		
2.0	.151	.133	.118	.129	.114	.102	.088	.079	.071	.051	.046	.042	.016	.015	.014		
3.0	.136	.113	.095	.117	.098	.083	.080	.068	.058	.046	.040	.034	.015	.013	.011		
4.0	.123	.098	.078	.106	.085	.068	.073	.059	.048	.042	.035	.028	.014	.011	.009		
5.0	.113	.086	.066	.097	.074	.057	.067	.052	.040	.039	.030	.024	.012	.010	.008		
6.0	.104	.076	.055	.089	.066	.048	.062	.046	.034	.036	.027	.020	.012	.009	.007		
7.0	.096	.068	.047	.083	.059	.041	.057	.041	.029	.033	.024	.017	.011	.008	.006		
8.0	.090	.061	.041	.077	.053	.036	.054	.037	.025	.031	.022	.015	.010	.007	.005		
9.0	.084	.055	.036	.072	.048	.031	.050	.034	.022	.029	.020	.013	.009	.007	.004		
10.0	.079	.050	.031	.068	.044	.027	.047	.031	.019	.028	.018	.012	.009	.006	.004		

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2023-09-14

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:240.4V I:0.0448A P:10.0W PF:0.9321 Freq:49.99Hz UTHDi:0.14% ITHDi:20.02% KDisp:0.9515 Lamp Flux:929.46lx1 lm										
NAME: MD10-10-XX-01 3000K RA90 15D					TYPE:			WEIGHT:		
SPEC.:					DIM.:			SERIAL No.:		
MFR.: Norming Lighting					SUR.:			Shielding Angle:		
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	16.5	17.1	16.7	17.3	17.4	15.2	15.9	15.4	16.0	16.2
3H	16.8	17.4	17.0	17.6	17.7	15.6	16.2	15.8	16.4	16.6
4H	16.8	17.4	17.1	17.6	17.8	15.7	16.3	15.9	16.5	16.7
6H	16.7	17.3	17.0	17.5	17.7	15.6	16.2	15.9	16.4	16.6
8H	16.7	17.2	17.0	17.5	17.7	15.6	16.1	15.9	16.4	16.6
12H	16.6	17.2	16.9	17.4	17.7	15.5	16.0	15.8	16.3	16.6
4H 2H	16.5	17.1	16.8	17.3	17.5	15.3	15.9	15.6	16.1	16.4
3H	16.9	17.4	17.2	17.6	17.9	15.9	16.4	16.2	16.6	16.9
4H	16.9	17.4	17.3	17.7	18.0	15.9	16.4	16.3	16.7	17.0
6H	16.8	17.3	17.2	17.6	17.9	15.9	16.3	16.2	16.6	17.0
8H	16.8	17.2	17.2	17.5	17.9	15.8	16.2	16.2	16.6	16.9
12H	16.7	17.1	17.1	17.5	17.9	15.8	16.1	16.2	16.5	16.9
8H 4H	16.8	17.2	17.2	17.6	17.9	15.9	16.3	16.3	16.6	17.0
6H	16.7	17.1	17.2	17.5	17.9	15.8	16.1	16.2	16.5	16.9
8H	16.7	17.0	17.1	17.4	17.8	15.7	16.0	16.2	16.4	16.9
12H	16.6	16.9	17.1	17.3	17.8	15.7	15.9	16.1	16.4	16.8
12H 4H	16.8	17.1	17.2	17.5	17.9	15.8	16.2	16.2	16.6	16.9
6H	16.7	17.0	17.1	17.4	17.8	15.7	16.0	16.2	16.4	16.9
8H	16.6	16.9	17.1	17.3	17.8	15.7	15.9	16.1	16.4	16.8
Variations with the observer position at spacings(CIE Pub.117):										
S = 1.0H	+ 2.2 / - 2.7					+ 1.4 / - 2.2				
1.5H	+ 3.9 / - 2.4					+ 2.8 / - 2.0				
2.0H	+ 3.0 / - 1.3					+ 1.7 / - 1.1				

CIE Pub.117, 929.5 lm Total Lamp Luminous Flux Corrected (8log(F/F0) = -0.3)
Area: 0.0013 m2

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2023-09-14

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:240.4V I:0.0448A P:10.0W PF:0.9321 Freq:49.99Hz		
UTHDi:0.14% ITHDi:20.02% KDisp:0.9515 Lamp Flux:929.46lx1 lm		
NAME: MD10-10-XX-01 3000K RA90 15D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.:	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	89	83	80	89	83	79	88	83	79	76
0.80	96	91	87	96	90	87	95	90	87	83
1.00	100	95	92	100	95	91	98	94	91	87
1.25	104	99	96	103	99	96	101	97	95	91
1.50	107	102	99	105	101	99	103	100	97	93
2.00	109	105	102	108	104	101	105	102	100	95
2.50	111	107	104	109	106	103	106	103	101	96
3.00	112	109	106	110	108	105	107	105	103	97
4.00	114	112	109	112	110	108	109	107	105	98
5.00	115	113	112	113	111	110	109	108	107	99
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2023-09-14

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:240.4V I:0.0448A P:10.0W PF:0.9321 Freq:49.99Hz		
UTHDi:0.14% ITHDi:20.02% KDisp:0.9515 Lamp Flux:929.46lx1 lm		
NAME: MD10-10-XX-01 3000K RA90 15D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.:	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2023-09-14

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

AAI Figure

Test:U:240.4V I:0.0448A P:10.0W PF:0.9321 Freq:49.99Hz		
UTHDi:0.14% ITHDi:20.02% KDisp:0.9515 Lamp Flux:929.46lx1 lm		
NAME: MD10-10-XX-01 3000K RA90 15D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.:	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2023-09-14

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

ISOLUX DIAGRAM

Test:U:240.4V I:0.0448A P:10.0W PF:0.9321 Freq:49.99Hz		
UTHDi:0.14% ITHDi:20.02% KDisp:0.9515 Lamp Flux:929.46lx1 lm		
NAME: MD10-10-XX-01 3000K RA90 15D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.:	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2023-09-14

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

LED Avg.L Report

Test:U:240.4V I:0.0448A P:10.0W PF:0.9321 Freq:49.99Hz		
UTHDi:0.14% ITHDi:20.02% KDisp:0.9515 Lamp Flux:929.461x1 lm		
NAME: MD10-10-XX-01 3000K RA90 15D	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Norming Lighting	SUR.:	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	11223
L_0~180 (75) av	6068
L_0~180 (85) av	1489
L_90~270 (65) av	10946
L_90~270 (75) av	4649
L_90~270 (85) av	149
L_45 (65) av	11085
L_45 (75) av	5898
L_45 (85) av	234

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:DAMIN
 Test Date:2023-09-14

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
 Humidity:65.0%
 Test Distance:3.090m [K=1.0000]
 Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: DAMIN
Test Date: 2023-09-14

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity: 65.0%
Test Distance: 3.090m [K=1.0000]
Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.453
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

```