



Indoor Luminaire Photometric Data

Description Information

Luminary Name: TR08-09-XX-01 3000K RA90 60D		Lum. Catalog:	Test ID: 01
Lamp Name:		Lamp Catalog: LED	Test Date: 2021/10/27
Manufacture: Shenzhen Norming Lighting Co., Ltd		Shld. Ang(°):	Test Machine:GON-2000
Test Lab: Quality Department		Frequency (Hz):	Lamp CCT (K): Ra:
Lum. Size (W*L*H):0.076m*0.076m*0.000m		Lum. Area (m2):0.005	Lum. W (kg): 0.000
Test System: C, γ	Test Step: C=90.0 γ=1.0	Temp. (°C): 25	Humidity(%): 50.0


Character Parameter

Lamp Speciality Parameter		Luminaire Speciality Parameter	
Rated Flux(lm): 773.350	Luminary Flux(lm): 773.352	Field Angle(10%Imax): 84.0(°)	
Rated Power(W):	Luminary Efficiency: 100.00%	Down Lumens&Percent: 766.732lm 99.14%	
Rated Voltage(V):	Luminary EER(lm/W): 87.553	Up Lumens&Percent: 6.620lm 0.86%	
Tested Power(W): 8.833	Max. Candela(cd): 792.704	S/MH: C0_a180=0.960 C90_270=0.957	
Lamps' Inside: 1	Max Cand@Ang. (°): C=0.0 γ=1.0	CIE Type: Semi-Direct	
Tested Electrics (V, A, pf):241.1, 0.040, 0.901	Beam Angle(50%Imax): 59.2(°)	ErP ϕ use(90°): 665.356lm	
Lamp Size (W*L*H):0.076m*0.076m*0.000m	Left=-28.4°, Right=30.8°	IRF(%): 219.368	



2D Plane Light Intensity Distribution Curve


Lum. Name:TR08-09-XX-01 3000K RA90 60D	Lum. Catalog:	Test ID:01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Shenzhen Norming Lighting Co., Ltd	Test Machine:GON-2000	Test Date: 2021/10/27



3D Light Intensity Distribution Modal

Lum. Name:TR08-09-XX-01 3000K RA90 60D	Lum. Catelog:	Test ID:01
Lamp Name:	Lamp Catelog:LED	Test Lab:Quality Department
Manufacture:Shenzhen Norming Lighting Co., Ltd	Test Machine:GON-2000	Test Date:2021/10/27

3D Light Intensity Distribution Modal



Zonal Flux Tabulation


Zone(γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone(γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
0.0-1.0	0.76	0.76	0.10	0.10	47.0-48.0	3.81	717.04	0.49	92.72
1.0-2.0	2.27	3.02	0.29	0.39	48.0-49.0	3.48	720.52	0.45	93.17
2.0-3.0	3.77	6.80	0.49	0.88	49.0-50.0	3.19	723.71	0.41	93.58
3.0-4.0	5.28	12.08	0.68	1.56	50.0-51.0	2.94	726.65	0.38	93.96
4.0-5.0	6.77	18.85	0.88	2.44	51.0-52.0	2.72	729.38	0.35	94.31
5.0-6.0	8.26	27.11	1.07	3.51	52.0-53.0	2.54	731.91	0.33	94.64
6.0-7.0	9.73	36.84	1.26	4.76	53.0-54.0	2.37	734.28	0.31	94.95
7.0-8.0	11.19	48.03	1.45	6.21	54.0-55.0	2.21	736.49	0.29	95.23
8.0-9.0	12.64	60.67	1.63	7.84	55.0-56.0	2.07	738.56	0.27	95.50
9.0-10.0	14.07	74.74	1.82	9.66	56.0-57.0	1.94	740.50	0.25	95.75
10.0-11.0	15.49	90.22	2.00	11.67	57.0-58.0	1.82	742.33	0.24	95.99
11.0-12.0	16.87	107.09	2.18	13.85	58.0-59.0	1.72	744.04	0.22	96.21
12.0-13.0	18.20	125.29	2.35	16.20	59.0-60.0	1.62	745.66	0.21	96.42
13.0-14.0	19.48	144.77	2.52	18.72	60.0-61.0	1.53	747.18	0.20	96.62
14.0-15.0	20.70	165.47	2.68	21.40	61.0-62.0	1.44	748.63	0.19	96.80
15.0-16.0	21.84	187.31	2.82	24.22	62.0-63.0	1.37	750.00	0.18	96.98
16.0-17.0	22.87	210.18	2.96	27.18	63.0-64.0	1.30	751.30	0.17	97.15
17.0-18.0	23.76	233.94	3.07	30.25	64.0-65.0	1.23	752.53	0.16	97.31
18.0-19.0	24.53	258.47	3.17	33.42	65.0-66.0	1.17	753.70	0.15	97.46
19.0-20.0	25.16	283.63	3.25	36.68	66.0-67.0	1.11	754.81	0.14	97.60
20.0-21.0	25.64	309.27	3.32	39.99	67.0-68.0	1.05	755.86	0.14	97.74
21.0-22.0	25.96	335.23	3.36	43.35	68.0-69.0	1.00	756.86	0.13	97.87
22.0-23.0	26.08	361.31	3.37	46.72	69.0-70.0	0.94	757.80	0.12	97.99
23.0-24.0	26.00	387.31	3.36	50.08	70.0-71.0	0.89	758.69	0.12	98.10
24.0-25.0	25.73	413.04	3.33	53.41	71.0-72.0	0.84	759.53	0.11	98.21
25.0-26.0	25.26	438.30	3.27	56.68	72.0-73.0	0.78	760.31	0.10	98.31
26.0-27.0	24.58	462.88	3.18	59.85	73.0-74.0	0.73	761.04	0.09	98.41
27.0-28.0	23.67	486.55	3.06	62.91	74.0-75.0	0.68	761.72	0.09	98.50
28.0-29.0	22.62	509.17	2.93	65.84	75.0-76.0	0.63	762.35	0.08	98.58
29.0-30.0	21.48	530.65	2.78	68.62	76.0-77.0	0.58	762.93	0.07	98.65
30.0-31.0	20.23	550.88	2.62	71.23	77.0-78.0	0.53	763.45	0.07	98.72
31.0-32.0	18.90	569.78	2.44	73.68	78.0-79.0	0.48	763.93	0.06	98.78
32.0-33.0	17.52	587.30	2.27	75.94	79.0-80.0	0.43	764.37	0.06	98.84
33.0-34.0	16.13	603.42	2.09	78.03	80.0-81.0	0.39	764.75	0.05	98.89
34.0-35.0	14.74	618.17	1.91	79.93	81.0-82.0	0.34	765.10	0.04	98.93
35.0-36.0	13.38	631.55	1.73	81.66	82.0-83.0	0.31	765.40	0.04	98.97
36.0-37.0	12.07	643.61	1.56	83.22	83.0-84.0	0.27	765.67	0.04	99.01
37.0-38.0	10.83	654.44	1.40	84.62	84.0-85.0	0.24	765.91	0.03	99.04
38.0-39.0	9.68	664.12	1.25	85.88	85.0-86.0	0.21	766.12	0.03	99.07
39.0-40.0	8.66	672.79	1.12	87.00	86.0-87.0	0.18	766.30	0.02	99.09
40.0-41.0	7.76	680.54	1.00	88.00	87.0-88.0	0.16	766.46	0.02	99.11
41.0-42.0	6.96	687.50	0.90	88.90	88.0-89.0	0.14	766.60	0.02	99.13
42.0-43.0	6.26	693.76	0.81	89.71	89.0-90.0	0.13	766.73	0.02	99.14
43.0-44.0	5.63	699.38	0.73	90.44	90.0-91.0	0.11	766.85	0.01	99.16
44.0-45.0	5.08	704.46	0.66	91.09	91.0-92.0	0.10	766.95	0.01	99.17
45.0-46.0	4.60	709.06	0.59	91.69	92.0-93.0	0.09	767.04	0.01	99.18
46.0-47.0	4.18	713.24	0.54	92.23	93.0-94.0	0.09	767.13	0.01	99.20

Zonal Flux Tabulation - (Cont.)

Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
94. 0-95. 0	0. 08	767. 21	0. 01	99. 21	141. 0-142. 0	0. 12	769. 60	0. 02	99. 51
95. 0-96. 0	0. 07	767. 28	0. 01	99. 21	142. 0-143. 0	0. 13	769. 72	0. 02	99. 53
96. 0-97. 0	0. 06	767. 34	0. 01	99. 22	143. 0-144. 0	0. 13	769. 85	0. 02	99. 55
97. 0-98. 0	0. 06	767. 40	0. 01	99. 23	144. 0-145. 0	0. 13	769. 98	0. 02	99. 56
98. 0-99. 0	0. 05	767. 46	0. 01	99. 24	145. 0-146. 0	0. 13	770. 12	0. 02	99. 58
99. 0-100. 0	0. 05	767. 50	0. 01	99. 24	146. 0-147. 0	0. 14	770. 25	0. 02	99. 60
100. 0-101. 0	0. 04	767. 55	0. 01	99. 25	147. 0-148. 0	0. 14	770. 39	0. 02	99. 62
101. 0-102. 0	0. 04	767. 59	0. 01	99. 25	148. 0-149. 0	0. 14	770. 52	0. 02	99. 63
102. 0-103. 0	0. 04	767. 62	0. 00	99. 26	149. 0-150. 0	0. 14	770. 66	0. 02	99. 65
103. 0-104. 0	0. 03	767. 65	0. 00	99. 26	150. 0-151. 0	0. 14	770. 80	0. 02	99. 67
104. 0-105. 0	0. 03	767. 68	0. 00	99. 27	151. 0-152. 0	0. 14	770. 94	0. 02	99. 69
105. 0-106. 0	0. 03	767. 71	0. 00	99. 27	152. 0-153. 0	0. 14	771. 08	0. 02	99. 71
106. 0-107. 0	0. 02	767. 73	0. 00	99. 27	153. 0-154. 0	0. 14	771. 21	0. 02	99. 72
107. 0-108. 0	0. 02	767. 75	0. 00	99. 28	154. 0-155. 0	0. 13	771. 35	0. 02	99. 74
108. 0-109. 0	0. 02	767. 77	0. 00	99. 28	155. 0-156. 0	0. 13	771. 48	0. 02	99. 76
109. 0-110. 0	0. 02	767. 78	0. 00	99. 28	156. 0-157. 0	0. 13	771. 61	0. 02	99. 78
110. 0-111. 0	0. 01	767. 80	0. 00	99. 28	157. 0-158. 0	0. 13	771. 74	0. 02	99. 79
111. 0-112. 0	0. 01	767. 81	0. 00	99. 28	158. 0-159. 0	0. 13	771. 87	0. 02	99. 81
112. 0-113. 0	0. 01	767. 83	0. 00	99. 29	159. 0-160. 0	0. 12	771. 99	0. 02	99. 82
113. 0-114. 0	0. 01	767. 84	0. 00	99. 29	160. 0-161. 0	0. 12	772. 11	0. 02	99. 84
114. 0-115. 0	0. 01	767. 85	0. 00	99. 29	161. 0-162. 0	0. 12	772. 22	0. 01	99. 85
115. 0-116. 0	0. 01	767. 86	0. 00	99. 29	162. 0-163. 0	0. 11	772. 33	0. 01	99. 87
116. 0-117. 0	0. 01	767. 88	0. 00	99. 29	163. 0-164. 0	0. 11	772. 44	0. 01	99. 88
117. 0-118. 0	0. 02	767. 90	0. 00	99. 29	164. 0-165. 0	0. 10	772. 54	0. 01	99. 90
118. 0-119. 0	0. 02	767. 92	0. 00	99. 30	165. 0-166. 0	0. 10	772. 64	0. 01	99. 91
119. 0-120. 0	0. 02	767. 94	0. 00	99. 30	166. 0-167. 0	0. 09	772. 73	0. 01	99. 92
120. 0-121. 0	0. 03	767. 96	0. 00	99. 30	167. 0-168. 0	0. 09	772. 82	0. 01	99. 93
121. 0-122. 0	0. 03	767. 99	0. 00	99. 31	168. 0-169. 0	0. 08	772. 90	0. 01	99. 94
122. 0-123. 0	0. 03	768. 03	0. 00	99. 31	169. 0-170. 0	0. 08	772. 98	0. 01	99. 95
123. 0-124. 0	0. 04	768. 06	0. 00	99. 32	170. 0-171. 0	0. 07	773. 05	0. 01	99. 96
124. 0-125. 0	0. 04	768. 11	0. 01	99. 32	171. 0-172. 0	0. 06	773. 11	0. 01	99. 97
125. 0-126. 0	0. 05	768. 15	0. 01	99. 33	172. 0-173. 0	0. 06	773. 17	0. 01	99. 98
126. 0-127. 0	0. 05	768. 21	0. 01	99. 33	173. 0-174. 0	0. 05	773. 21	0. 01	99. 98
127. 0-128. 0	0. 06	768. 26	0. 01	99. 34	174. 0-175. 0	0. 04	773. 26	0. 01	99. 99
128. 0-129. 0	0. 06	768. 33	0. 01	99. 35	175. 0-176. 0	0. 03	773. 29	0. 00	99. 99
129. 0-130. 0	0. 07	768. 40	0. 01	99. 36	176. 0-177. 0	0. 03	773. 32	0. 00	100. 00
130. 0-131. 0	0. 07	768. 47	0. 01	99. 37	177. 0-178. 0	0. 02	773. 34	0. 00	100. 00
131. 0-132. 0	0. 08	768. 55	0. 01	99. 38	178. 0-179. 0	0. 01	773. 35	0. 00	100. 00
132. 0-133. 0	0. 08	768. 63	0. 01	99. 39	179. 0-180. 0	0. 00	773. 35	0. 00	100. 00
133. 0-134. 0	0. 09	768. 72	0. 01	99. 40					
134. 0-135. 0	0. 09	768. 81	0. 01	99. 41					
135. 0-136. 0	0. 10	768. 91	0. 01	99. 43					
136. 0-137. 0	0. 10	769. 02	0. 01	99. 44					
137. 0-138. 0	0. 11	769. 13	0. 01	99. 45					
138. 0-139. 0	0. 11	769. 24	0. 01	99. 47					
139. 0-140. 0	0. 12	769. 35	0. 01	99. 48					
140. 0-141. 0	0. 12	769. 47	0. 02	99. 50					

Rectangle ISO Lighting Intensity Diagram

Lum. Name:TR08-09-XX-01 3000K RA90 60D	Lum. Catalog:	Test ID:01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Shenzhen Norming Lighting Co., Ltd	Test Machine:GON-2000	Test Date: 2021/10/27




Maximum Light Intensity(cd): 792.70

Maximum Cand.@Angle: H=1.0°,V=0.0°

Plane ISO-Illuminance Diagram

Lum. Name:TR08-09-XX-01 3000K RA90 60D	Lum. Catalog:	Test ID:01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Shenzhen Norming Lighting Co., Ltd	Test Machine:GON-2000	Test Date: 2021/10/27

Plane ISO-Illuminance Curve



Working Plane Luminaire Mounting Height(m): 3.00
Working Plane Maximum Illuminance(lx): 88.04
Working Plane Maximum Illuminance Position(d/h):H0.0 V0.0


IES Indoor Report

Photometric Filename:TR08-09-XX-01 3000K RA90 60D.IES

3D Plane ISO Illuminance Diagram

Lum. Name: TR08-09-XX-01 3000K RA90 60D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Shenzhen Norming Lighting Co., Ltd	Test Machine:GON-2000	Test Date: 2021/10/27

3D Plane Illuminance Modal




Curves: 3D Model — 90% — 80% — 70% — 60% — 50% — 40% — 30% — 20% — 10% —
View Angles(deg): 0 Height(m): 3.0 Distance(m): 10.0

Space ISO Illuminance Diagram

Lum. Name:TR08-09-XX-01 3000K RA90 60D	Lum. Catelog:	Test ID:01
Lamp Name:	Lamp Catelog:LED	Test Lab:Quality Department
Manufacture:Shenzhen Norming Lighting Co., Ltd	Test Machine:GON-2000	Test Date:2021/10/27


Space ISO Illuminance Curve



Space Plane Maximum Illuminance and @Angle:792.34lx,1.0deg
Plane Maximum Lighting Intensity and @Angle:792.704cd,0eg

Illuminance-Distance Diagram

Lum. Name:TR08-09-XX-01 3000K RA90 60D	Lum. Catelog:	Test ID:01
Lamp Name:	Lamp Catelog:LED	Test Lab:Quality Department
Manufacture:Shenzhen Norming Lighting Co., Ltd	Test Machine:GON-2000	Test Date:2021/10/27



Indoor Luminance Limiting Curves

Lum. Name: TR08-09-XX-01 3000K RA90 60D	Lum. Catalog:	Test ID: 01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Shenzhen Norming Lighting Co., Ltd	Test Machine:GON-2000	Test Date: 2021/10/27


Glare Grade Table

GI	Quality	Using Illuminance							
1.15	A	2000	1000	500	<=300				
1.5	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.2	D				2000	1000	500	<=300	
2.55	E	a				2000	1000	500	<=300
			b	c	d	e	f	g	h

Luminance Table

Gama(deg)	45	50	55	60	65	70	75	80	85
C0	20546	13556	9957	7972	6886	6375	5893	5775	6012
C90	10539	7671	6041	5092	4416	3700	2923	1765	1576

Luminance Limiting Curve




Luminous Size: Length(m)=-0.076 Width(m)=-0.076 Height(m)=0.000 Area(m^2)=0.004536

Luminous Type: Without Luminous Side

Luminous Curves: C0-C180 Color: C90-C270 Color:

Indoor Budgetary Estimate Table

Lum. Name:TR08-09-XX-01 3000K RA90 60D	Lum. Catalog:	Test ID:01
Lamp Name:	Lamp Catalog: LED	Test Lab: Quality Department
Manufacture: Shenzhen Norming Lighting Co., Ltd	Test Machine:GON-2000	Test Date: 2021/10/27



Indoor Coefficient of Utilization Table

Lum. Name:TR08-09-XX-01 3000K RA90 60D	Lum. Catelog:	Test ID:01
Lamp Name:	Lamp Catelog:LED	Test Lab:Quality Department
Manufacture:Shenzhen Norming Lighting Co., Ltd	Test Machine:GON-2000	Test Date:2021/10/27

Coefficients of Utilization - Zonal Cavity Method																		
Coef.	Effective Floor Cavity Reflectance RFC=0.20																	
RhoCC (%)	80				70				50			30			10			0
RhoW (%)	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR	Coefficient of Utilization(%)																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	113	110	107	105	110	108	105	103	103	101	100	99	98	97	96	95	94	92
2	107	102	97	94	104	100	96	93	96	93	90	93	91	88	90	88	86	85
3	101	94	89	85	99	93	88	84	90	86	83	87	84	81	85	82	80	78
4	96	88	82	77	94	87	81	77	84	80	76	82	78	75	80	77	74	72
5	91	82	76	71	89	81	75	71	79	74	70	77	73	70	76	72	69	67
6	86	77	70	66	84	76	70	66	74	69	65	73	68	65	71	67	64	63
7	82	72	66	61	80	71	65	61	70	65	61	69	64	60	67	63	60	59
8	78	68	62	57	76	67	61	57	66	61	57	65	60	57	64	59	56	55
9	74	64	58	54	73	63	58	54	62	57	53	61	57	53	60	56	53	51
10	70	60	54	50	69	60	54	50	59	54	50	58	53	50	57	53	50	48

Unified Glare Rating Table

Lum. Name:TR08-09-XX-01 3000K RA90 60D	Lum. Catelog:	Test ID:01
Lamp Name:	Lamp Catelog:LED	Test Lab:Quality Department
Manufacture:Shenzhen Norming Lighting Co., Ltd	Test Machine:GON-2000	Test Date:2021/10/27

Unified Glare Rating Table

Ceiling RCC	0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
Wall RW	0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
Floor RFC	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room Size	Vewed crosswise					Vewed endwise				
X=2H Y=2H	19.3	20.5	19.7	20.8	21.1	15.3	16.5	15.7	16.8	17.1
	19.5	20.5	19.9	20.8	21.2	15.6	16.6	16.0	16.9	17.3
	19.6	20.5	20.0	20.9	21.3	15.6	16.6	16.1	17.0	17.4
	19.6	20.5	20.1	20.9	21.3	15.6	16.5	16.1	16.9	17.3
	19.6	20.5	20.1	20.9	21.3	15.6	16.4	16.0	16.8	17.3
	19.6	20.5	20.1	20.9	21.3	15.5	16.4	16.0	16.8	17.2
X=4H Y=2H	19.2	20.2	19.7	20.6	21.0	15.4	16.3	15.8	16.7	17.1
	19.5	20.3	19.9	20.7	21.1	15.8	16.6	16.2	17.0	17.4
	19.6	20.4	20.1	20.8	21.3	15.9	16.6	16.4	17.1	17.5
	19.8	20.4	20.3	20.9	21.4	15.9	16.6	16.4	17.0	17.5
	19.8	20.4	20.3	20.9	21.4	15.9	16.5	16.4	17.0	17.5
	19.9	20.4	20.4	20.9	21.4	15.9	16.4	16.4	16.9	17.4
X=8H Y=4H	19.6	20.2	20.1	20.7	21.2	15.9	16.5	16.4	17.0	17.5
	19.8	20.3	20.3	20.8	21.4	16.0	16.5	16.5	17.0	17.6
	19.9	20.4	20.5	20.9	21.4	16.0	16.5	16.5	17.0	17.5
	20.0	20.5	20.6	21.0	21.6	16.0	16.4	16.5	16.9	17.5
X=12H Y=4H	19.6	20.1	20.1	20.6	21.1	15.9	16.4	16.4	16.9	17.4
	19.8	20.3	20.3	20.8	21.3	16.0	16.5	16.5	16.9	17.5
	20.0	20.4	20.5	20.9	21.5	16.0	16.4	16.5	16.9	17.5
Variations with the objverver position at spacings										
S=1.0H	0.4/-0.4					0.8/-0.9				
S=1.5H	0.7/-0.8					1.3/-1.7				
S=2.0H	1.0/-1.1					1.7/-2.2				
Reduced UGR Table:										
Nordic Standard Table:	BK0					BK0				
Correction Value	0.9					0.9				

o the CIE Pub.117,data has been corrected,refers to the lamp’s lumens 8.2flm.

Candela Tabulation

V/H	C0.0	C90.0	C180.0	C270.0
γ 0.0	790.76	790.76	790.76	790.76
γ 1.0	792.70	786.72	791.25	789.95
γ 2.0	792.48	785.39	789.70	790.29
γ 3.0	792.59	782.91	788.37	790.97
γ 4.0	791.96	781.83	786.88	791.41
γ 5.0	790.80	779.48	785.38	791.07
γ 6.0	787.66	777.21	784.03	790.91
γ 7.0	784.23	774.04	782.26	790.80
γ 8.0	780.89	771.82	780.06	789.99
γ 9.0	778.53	768.60	778.13	789.27
γ 10.0	777.38	762.85	778.08	786.80
γ 11.0	775.62	756.35	776.23	785.75
γ 12.0	775.04	744.57	773.14	784.70
γ 13.0	774.67	730.69	770.26	780.56
γ 14.0	773.96	713.67	766.14	778.24
γ 15.0	773.82	692.38	760.09	773.95
γ 16.0	770.61	668.94	751.03	771.51
γ 17.0	762.57	643.82	736.31	768.74
γ 18.0	750.59	619.33	716.71	767.04
γ 19.0	736.32	591.25	694.13	763.95
γ 20.0	719.25	561.73	671.33	760.42
γ 21.0	699.57	529.13	646.22	754.00
γ 22.0	677.90	495.30	619.00	745.41
γ 23.0	653.34	458.92	588.29	733.32
γ 24.0	627.03	423.28	555.84	716.89
γ 25.0	597.78	386.04	521.94	697.36
γ 26.0	566.24	348.69	488.02	675.04
γ 27.0	531.15	310.44	450.50	648.06
γ 28.0	494.52	273.23	412.40	618.93
γ 29.0	459.95	238.42	372.30	589.06
γ 30.0	425.11	206.09	332.65	558.03
γ 31.0	389.24	177.81	293.73	525.14
γ 32.0	352.74	153.52	256.42	490.48
γ 33.0	315.67	132.97	222.12	454.94
γ 34.0	279.94	115.54	192.57	417.86
γ 35.0	245.09	101.04	167.06	379.86
γ 36.0	212.94	88.69	145.27	340.88
γ 37.0	184.54	78.04	126.61	302.82
γ 38.0	159.65	69.19	110.70	265.80
γ 39.0	138.46	61.66	97.09	232.34
γ 40.0	120.96	55.14	85.29	202.48
γ 41.0	106.15	49.57	75.28	176.31
γ 42.0	93.68	44.75	66.68	153.74
γ 43.0	83.04	40.66	59.06	133.84
γ 44.0	73.80	36.97	52.41	116.76
γ 45.0	65.91	33.81	46.77	102.21
γ 46.0	58.94	31.00	41.89	89.77

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 47.0	52.92	28.50	37.69	79.29
γ 48.0	47.72	26.21	34.10	70.23
γ 49.0	43.38	24.24	30.96	62.10
γ 50.0	39.53	22.37	28.24	55.33
γ 51.0	36.11	20.73	25.88	49.76
γ 52.0	33.09	19.25	23.77	45.34
γ 53.0	30.36	17.96	21.96	41.49
γ 54.0	28.05	16.79	20.32	37.85
γ 55.0	25.91	15.72	18.89	34.59
γ 56.0	24.00	14.77	17.63	31.68
γ 57.0	22.34	13.87	16.44	29.06
γ 58.0	20.79	13.04	15.41	26.74
γ 59.0	19.35	12.27	14.51	24.64
γ 60.0	18.08	11.55	13.69	22.77
γ 61.0	16.93	10.89	12.94	21.14
γ 62.0	15.86	10.23	12.26	19.69
γ 63.0	14.90	9.61	11.62	18.41
γ 64.0	14.02	9.02	11.00	17.26
γ 65.0	13.20	8.47	10.40	16.25
γ 66.0	12.46	7.93	9.81	15.27
γ 67.0	11.76	7.37	9.24	14.45
γ 68.0	11.12	6.79	8.69	13.68
γ 69.0	10.48	6.22	8.16	12.98
γ 70.0	9.89	5.74	7.64	12.30
γ 71.0	9.28	5.29	7.06	11.65
γ 72.0	8.69	4.81	6.51	11.03
γ 73.0	8.09	4.32	6.02	10.46
γ 74.0	7.48	3.85	5.53	9.89
γ 75.0	6.92	3.43	5.07	9.34
γ 76.0	6.44	3.04	4.56	8.67
γ 77.0	6.01	2.48	4.09	8.02
γ 78.0	5.54	2.02	3.65	7.45
γ 79.0	5.05	1.70	3.30	6.94
γ 80.0	4.55	1.39	2.87	6.39
γ 81.0	4.11	1.13	2.24	5.89
γ 82.0	3.70	0.96	1.90	5.38
γ 83.0	3.14	0.83	1.66	4.98
γ 84.0	2.70	0.73	1.40	4.46
γ 85.0	2.38	0.62	1.20	3.99
γ 86.0	2.07	0.55	1.07	3.44
γ 87.0	1.82	0.49	0.96	2.92
γ 88.0	1.63	0.41	0.83	2.61
γ 89.0	1.49	0.37	0.75	2.29
γ 90.0	1.37	0.31	0.68	2.02
γ 91.0	1.27	0.25	0.62	1.81
γ 92.0	1.19	0.21	0.55	1.67
γ 93.0	1.10	0.15	0.49	1.53

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 94.0	1.02	0.09	0.43	1.43
γ 95.0	0.95	0.05	0.38	1.35
γ 96.0	0.87	0.01	0.34	1.26
γ 97.0	0.80	0.00	0.29	1.17
γ 98.0	0.73	0.00	0.25	1.08
γ 99.0	0.67	0.00	0.20	1.01
γ 100.0	0.60	0.00	0.17	0.94
γ 101.0	0.55	0.00	0.13	0.86
γ 102.0	0.48	0.00	0.11	0.80
γ 103.0	0.44	0.00	0.07	0.74
γ 104.0	0.39	0.00	0.05	0.69
γ 105.0	0.35	0.00	0.03	0.63
γ 106.0	0.30	0.00	0.01	0.59
γ 107.0	0.26	0.00	0.01	0.53
γ 108.0	0.23	0.00	0.00	0.50
γ 109.0	0.21	0.00	0.00	0.45
γ 110.0	0.18	0.00	0.00	0.41
γ 111.0	0.17	0.00	0.00	0.39
γ 112.0	0.14	0.00	0.01	0.37
γ 113.0	0.14	0.00	0.02	0.35
γ 114.0	0.13	0.00	0.05	0.32
γ 115.0	0.13	0.00	0.07	0.31
γ 116.0	0.14	0.01	0.10	0.29
γ 117.0	0.15	0.06	0.14	0.29
γ 118.0	0.16	0.11	0.18	0.30
γ 119.0	0.18	0.17	0.22	0.29
γ 120.0	0.20	0.22	0.27	0.31
γ 121.0	0.24	0.29	0.32	0.32
γ 122.0	0.27	0.36	0.38	0.34
γ 123.0	0.32	0.43	0.44	0.37
γ 124.0	0.37	0.50	0.50	0.40
γ 125.0	0.42	0.58	0.58	0.43
γ 126.0	0.48	0.65	0.64	0.47
γ 127.0	0.53	0.75	0.72	0.52
γ 128.0	0.59	0.82	0.80	0.57
γ 129.0	0.66	0.91	0.88	0.63
γ 130.0	0.73	0.99	0.96	0.69
γ 131.0	0.81	1.08	1.05	0.75
γ 132.0	0.88	1.17	1.14	0.82
γ 133.0	0.96	1.25	1.22	0.88
γ 134.0	1.03	1.34	1.31	0.95
γ 135.0	1.12	1.43	1.40	1.02
γ 136.0	1.20	1.53	1.49	1.10
γ 137.0	1.28	1.62	1.58	1.18
γ 138.0	1.36	1.71	1.66	1.26
γ 139.0	1.44	1.79	1.75	1.34
γ 140.0	1.53	1.89	1.86	1.41

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 141.0	1.62	1.98	1.93	1.48
γ 142.0	1.71	2.08	2.04	1.58
γ 143.0	1.80	2.15	2.12	1.67
γ 144.0	1.88	2.24	2.21	1.74
γ 145.0	1.97	2.32	2.30	1.83
γ 146.0	2.07	2.40	2.39	1.91
γ 147.0	2.16	2.48	2.47	2.00
γ 148.0	2.24	2.56	2.55	2.08
γ 149.0	2.33	2.63	2.64	2.17
γ 150.0	2.41	2.70	2.71	2.26
γ 151.0	2.49	2.78	2.79	2.35
γ 152.0	2.58	2.85	2.87	2.43
γ 153.0	2.65	2.90	2.93	2.51
γ 154.0	2.73	2.96	3.00	2.59
γ 155.0	2.80	3.04	3.07	2.67
γ 156.0	2.88	3.10	3.13	2.74
γ 157.0	2.95	3.16	3.20	2.82
γ 158.0	3.02	3.22	3.26	2.89
γ 159.0	3.08	3.28	3.32	2.95
γ 160.0	3.15	3.33	3.38	3.03
γ 161.0	3.22	3.39	3.43	3.10
γ 162.0	3.30	3.46	3.49	3.15
γ 163.0	3.36	3.52	3.54	3.22
γ 164.0	3.43	3.58	3.58	3.29
γ 165.0	3.47	3.63	3.65	3.35
γ 166.0	3.54	3.69	3.69	3.41
γ 167.0	3.60	3.74	3.75	3.47
γ 168.0	3.67	3.78	3.79	3.53
γ 169.0	3.72	3.83	3.85	3.59
γ 170.0	3.78	3.87	3.87	3.65
γ 171.0	3.83	3.90	3.91	3.71
γ 172.0	3.88	3.93	3.94	3.76
γ 173.0	3.93	3.97	3.99	3.82
γ 174.0	3.98	3.98	4.01	3.86
γ 175.0	4.02	4.01	4.03	3.91
γ 176.0	4.03	4.02	4.04	3.96
γ 177.0	4.06	4.04	4.06	3.99
γ 178.0	4.09	4.03	4.08	4.03
γ 179.0	4.09	4.03	4.07	4.07
γ 180.0	4.07	4.07	4.07	4.07